



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J012113

Afton Central School District

Project Name: Lead

Brian Phetteplace
29 Academy Street
Afton, NY 13730

Project / PO Number: N/A
Received: 09/28/2020
Reported: 10/25/2020

Analytical Testing Parameters

Client Sample ID:	Elementary entrance bubbler	Collected By:	Customer
Sample Matrix:	Drinking Water	Collection Date:	09/17/2020 5:35
Lab Sample ID:	J012113-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1729	LLW

Client Sample ID:	Room 2 Faucet	Collected By:	Customer
Sample Matrix:	Drinking Water	Collection Date:	09/17/2020 5:37
Lab Sample ID:	J012113-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0117	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1735	LLW

Client Sample ID:	Room 3 Faucet A	Collected By:	Customer
Sample Matrix:	Drinking Water	Collection Date:	09/17/2020 5:37
Lab Sample ID:	J012113-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/07/20 1445	10/09/20 1344	LLW

Client Sample ID:	Room 3 Faucet B	Collected By:	Customer
Sample Matrix:	Drinking Water	Collection Date:	09/17/2020 5:37
Lab Sample ID:	J012113-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1736	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 3 Faucet C	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 5:40
Lab Sample ID: J0I2113-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1738	LLW

Client Sample ID: Room 4 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 5:40
Lab Sample ID: J0I2113-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1740	LLW

Client Sample ID: Room 4 Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 5:40
Lab Sample ID: J0I2113-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1742	LLW

Client Sample ID: Room 5 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 5:44
Lab Sample ID: J0I2113-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0039	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1747	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 5 Bubblers	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 5:44
Lab Sample ID: J0I2113-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1749	LLW

Client Sample ID: Room 6 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 5:46
Lab Sample ID: J0I2113-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1751	LLW

Client Sample ID: Room 6 Bubblers	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 5:46
Lab Sample ID: J0I2113-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1753	LLW

Client Sample ID: Room 7 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 5:50
Lab Sample ID: J0I2113-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1755	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 7 Bubblers	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 5:50
Lab Sample ID: J0I2113-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1758	LLW

Client Sample ID: Room 23 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 5:57
Lab Sample ID: J0I2113-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1800	LLW

Client Sample ID: Room 23 Bubblers	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 5:57
Lab Sample ID: J0I2113-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1802	LLW

Client Sample ID: Lower B section Bubblers	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 5:55
Lab Sample ID: J0I2113-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1804	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 101 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:10
Lab Sample ID: J0I2113-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1809	LLW

Client Sample ID: Room 101 Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:10
Lab Sample ID: J0I2113-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1811	LLW

Client Sample ID: Room 102 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:13
Lab Sample ID: J0I2113-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1813	LLW

Client Sample ID: Room 102 Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:13
Lab Sample ID: J0I2113-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1815	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 103 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:15
Lab Sample ID: J0I2113-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/07/20 1600	10/07/20 1817	LLW

Client Sample ID: Room 103 Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:15
Lab Sample ID: J0I2113-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/07/20 1607	10/07/20 1826	LLW

Client Sample ID: Room 104 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:18
Lab Sample ID: J0I2113-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.0150 AL	0.0010	mg/L		10/07/20 1607	10/07/20 1832	LLW

Client Sample ID: Room 104 Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:18
Lab Sample ID: J0I2113-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.0150 AL	0.0010	mg/L		10/07/20 1607	10/07/20 1833	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 105 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:35
Lab Sample ID: J0I2113-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0038	0.0150 AL	0.0010	mg/L		10/07/20 1607	10/07/20 1835	LLW

Client Sample ID: Room 105 Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:35
Lab Sample ID: J0I2113-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.0150 AL	0.0010	mg/L		10/07/20 1607	10/07/20 1837	LLW

Client Sample ID: Room 106 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:38
Lab Sample ID: J0I2113-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0064	0.0150 AL	0.0010	mg/L		10/07/20 1607	10/07/20 1843	LLW

Client Sample ID: Room 106 Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:38
Lab Sample ID: J0I2113-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.0150 AL	0.0010	mg/L		10/07/20 1607	10/07/20 1845	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 107 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:41
Lab Sample ID: J0I2113-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.0150 AL	0.0010	mg/L		10/07/20 1607	10/07/20 1847	LLW

Client Sample ID: Room 107 Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:41
Lab Sample ID: J0I2113-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/07/20 1607	10/07/20 1848	LLW

Client Sample ID: Hall E. Cafeteria Bubblers	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:43
Lab Sample ID: J0I2113-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/07/20 1607	10/07/20 1850	LLW

Client Sample ID: Elem. Kitchen Faucet A	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:45
Lab Sample ID: J0I2113-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/07/20 1607	10/07/20 1852	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Elem. Kitchen Faucet B	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:45
Lab Sample ID: J0I2113-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/07/20 1607	10/07/20 1856	LLW

Client Sample ID: Elem. Kitchen Faucet C	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:45
Lab Sample ID: J0I2113-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0017	0.0150 AL	0.0010	mg/L		10/07/20 1607	10/07/20 1858	LLW

Client Sample ID: Room 110 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/17/2020 6:50
Lab Sample ID: J0I2113-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0017	0.0150 AL	0.0010	mg/L		10/08/20 1401	10/08/20 1807	LLW

Client Sample ID: Elem. Teacher Room Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:25
Lab Sample ID: J0I2113-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0109	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1844	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Copy Room Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:28
Lab Sample ID: J0I2113-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0182	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1849	LLW

Client Sample ID: Room 202 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:15
Lab Sample ID: J0I2113-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1851	LLW

Client Sample ID: Room 202 Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:45
Lab Sample ID: J0I2113-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0056	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1853	LLW

Client Sample ID: Room 203 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:47
Lab Sample ID: J0I2113-40	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0100	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1855	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 203 Bubler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:47
Lab Sample ID: J0I2113-41	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.0150 AL	0.0010	mg/L		10/09/20 1348	10/12/20 1224	LLW

Client Sample ID: Room 204 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:50
Lab Sample ID: J0I2113-42	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0055	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1857	LLW

Client Sample ID: Room 204 Bubler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:50
Lab Sample ID: J0I2113-43	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1902	LLW

Client Sample ID: Room 205 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:54
Lab Sample ID: J0I2113-44	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1904	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 205 Bubler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:54
Lab Sample ID: J0I2113-45	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1906	LLW

Client Sample ID: Room 206 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:57
Lab Sample ID: J0I2113-46	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.0150 AL	0.0010	mg/L		10/09/20 1348	10/12/20 1216	LLW

Client Sample ID: Room 206 Bubler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:57
Lab Sample ID: J0I2113-47	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0111	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1908	LLW

Client Sample ID: Room 207 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:00
Lab Sample ID: J0I2113-48	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1910	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 207 Bubler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:00
Lab Sample ID: J0I2113-49	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0056	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1913	LLW

Client Sample ID: Room 208 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:05
Lab Sample ID: J0I2113-50	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1915	LLW

Client Sample ID: Room 208 Bubler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:05
Lab Sample ID: J0I2113-51	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0061	0.0150 AL	0.0010	mg/L		10/09/20 1348	10/12/20 1225	LLW

Client Sample ID: Room 209 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:08
Lab Sample ID: J0I2113-52	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0065	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1917	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 209 Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:08
Lab Sample ID: J0I2113-53	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1919	LLW

Client Sample ID: Room 210 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:10
Lab Sample ID: J0I2113-54	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0051	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 1942	LLW

Client Sample ID: Room 210 Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:10
Lab Sample ID: J0I2113-55	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1925	LLW

Client Sample ID: Room 211 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:14
Lab Sample ID: J0I2113-56	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1927	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 211 Bubler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:14
Lab Sample ID: J0I2113-57	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0081	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1928	LLW

Client Sample ID: Elem. 2nd Floor Bubler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:10
Lab Sample ID: J0I2113-58	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1930	LLW

Client Sample ID: Room 212 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:15
Lab Sample ID: J0I2113-59	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.0150 AL	0.0010	mg/L		10/09/20 1348	10/12/20 1227	LLW

Client Sample ID: Room 212 Bubler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:15
Lab Sample ID: J0I2113-60	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0095	0.0150 AL	0.0010	mg/L		10/09/20 1348	10/12/20 1229	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 213 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:15
Lab Sample ID: J0I2113-61	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1418	10/08/20 1932	LLW

Client Sample ID: Room 213 Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:15
Lab Sample ID: J0I2113-62	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0104	0.0150 AL	0.0010	mg/L		10/09/20 1348	10/12/20 1235	LLW

Client Sample ID: Room 214 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:18
Lab Sample ID: J0I2113-63	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0064	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 1947	LLW

Client Sample ID: Room 214 Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:18
Lab Sample ID: J0I2113-64	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 1949	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: 2nd Floor 6th grade Bubbler A	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:20
Lab Sample ID: J0I2113-65	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 1951	LLW

Client Sample ID: 2nd Floor 6th grade Bubbler B	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:20
Lab Sample ID: J0I2113-66	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 1953	LLW

Client Sample ID: Room 122 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:30
Lab Sample ID: J0I2113-67	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 2008	LLW

Client Sample ID: Laundry Room Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:35
Lab Sample ID: J0I2113-68	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 2012	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Laundry Room Ice Machine	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:35
Lab Sample ID: J0I2113-69	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 2014	LLW

Client Sample ID: Hall between Pool & Gym Bubblers	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 7:40
Lab Sample ID: J0I2113-70	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0069	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 2015	LLW

Client Sample ID: Nurse's Office Faucet A	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:33
Lab Sample ID: J0I2113-71	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0030	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 2017	LLW

Client Sample ID: Nurse's Office Faucet B	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:33
Lab Sample ID: J0I2113-72	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0908	0.0150 AL	0.0200	mg/L	D	10/09/20 1348	10/13/20 1252	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: H.S. Teachers Room Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:35
Lab Sample ID: J0I2113-73	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 2023	LLW

Client Sample ID: Hall by H.S. Cafe Bubblers	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:40
Lab Sample ID: J0I2113-74	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 2025	LLW

Client Sample ID: H.S. cafe Faucet A	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:30
Lab Sample ID: J0I2113-75	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 2027	LLW

Client Sample ID: H.S. cafe Faucet B	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:30
Lab Sample ID: J0I2113-76	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 2029	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: H.S. cafe Faucet C	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:30
Lab Sample ID: J0I2113-77	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1429	10/08/20 2031	LLW

Client Sample ID: H.S. cafe Faucet D	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:30
Lab Sample ID: J0I2113-78	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2040	LLW

Client Sample ID: H.S. cafe Faucet E	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:30
Lab Sample ID: J0I2113-79	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2046	LLW

Client Sample ID: Home Ec. Faucet A	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:15
Lab Sample ID: J0I2113-80	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2048	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Home Ec. Faucet B	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:25
Lab Sample ID: J0I2113-81	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2050	LLW

Client Sample ID: Home Ec. Faucet C	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:26
Lab Sample ID: J0I2113-82	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2052	LLW

Client Sample ID: Home Ec. Faucet D	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:26
Lab Sample ID: J0I2113-83	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2053	LLW

Client Sample ID: Home Ec. Faucet E	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:27
Lab Sample ID: J0I2113-84	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2059	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Home Ec. Faucet F	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:25
Lab Sample ID: J0I2113-85	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2101	LLW

Client Sample ID: Room 151 Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:20
Lab Sample ID: J0I2113-86	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2103	LLW

Client Sample ID: Hall by Aud. Bubbler A	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:45
Lab Sample ID: J0I2113-87	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2105	LLW

Client Sample ID: Hall by Aud Bubbler B	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:45
Lab Sample ID: J0I2113-88	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2107	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Hall by Art Room Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:50
Lab Sample ID: J0I2113-89	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2111	LLW

Client Sample ID: GED Room Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:53
Lab Sample ID: J0I2113-90	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2113	LLW

Client Sample ID: Bus garage Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 8:10
Lab Sample ID: J0I2113-91	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2115	LLW

Client Sample ID: Room 34 Faucet A	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:25
Lab Sample ID: J0I2113-92	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2117	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Room 34 Faucet B	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:25
Lab Sample ID: J0I2113-93	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/08/20 2122	LLW

Client Sample ID: Main Lobby Bubbler A	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:15
Lab Sample ID: J0I2113-94	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/09/20 1004	LLW

Client Sample ID: Main Lobby Bubbler B	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:15
Lab Sample ID: J0I2113-95	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/09/20 1002	LLW

Client Sample ID: H.S. Boy's Locker Room Bubbler	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:20
Lab Sample ID: J0I2113-96	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/09/20 1001	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: H.S. Girl's Locker Room Bubblers	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:20
Lab Sample ID: J0I2113-97	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/08/20 1436	10/09/20 0953	LLW

Client Sample ID: Over Look Bubblers	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:10
Lab Sample ID: J0I2113-98	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/10/20 1225	10/10/20 2041	LLW

Client Sample ID: Band Room Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:00
Lab Sample ID: J0I2113-99	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.0150 AL	0.0010	mg/L		10/10/20 1225	10/10/20 2052	LLW

Client Sample ID: Cust. Break Room Faucet	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:10
Lab Sample ID: J0I2113-AA	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/10/20 1225	10/10/20 2058	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0I2113

Client Sample ID: Pool Area Bubblers	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:30
Lab Sample ID: J0I2113-AB	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/10/20 1225	10/10/20 2100	LLW

Client Sample ID: Hall by H.S. Cafe Bottle Fill	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 5:40
Lab Sample ID: J0I2113-AC	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/10/20 1225	10/10/20 2101	LLW

Client Sample ID: Over Look Bottle Fill	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 09/15/2020 6:10
Lab Sample ID: J0I2113-AD	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/10/20 1225	10/10/20 2103	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- D:** The sample was diluted due to matrix interference.
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J012113

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

A handwritten signature in black ink that reads "Jennifer M. Walker".

Jennifer Walker

Operations Manager

Reported: 10/25/2020 11:20

Microbac Laboratories, Inc. Samples must be returned on ice

CHAIN OF CUSTODY

MNY Workorder # _____



Afton Central School District
 PM: Shannon Weeks

Client Information		Billing/Invoice:	
Name: Afton CSD		Same as Client	
Address: PO Box 5, 29 Academy St Afton, NY 13730-0005			
Contact: Brian Phetteplace			
Phone: 607-639-8220			
Project: Main Building			
Quote ID: _____		PO#: _____	
Rush TAT Bus. Days: *2 2-5 5-7 7-10		Date Req: _____	
Carbon Copy: Yes			
Email Results: Yes bphetteplace@aftoncsd.org			
Fax Results: Yes 607-639-1801			
Sample Information			
Description/Location	Date	Time	Matrix Type
1 Elementary entrance bubbler	9-17-2020	5:35	Grab
2 Room 2 Faucet	9-17-2020	5:37	Grab
3 Room 3 Faucet A	9-17-2020	5:37	Grab
4 Room 3 Faucet B	9-17-2020	5:37	Grab
5 Room 3 Faucet C	9-17-2020	5:40	Grab
6 Room 4 Faucet	9-17-2020	5:40	Grab
7 Room 4 Bubbler	9-17-2020	5:40	Grab
8 Room 5 Faucet	9-17-2020	5:44	Grab
9 Room 5 Bubbler	9-17-2020	5:44	Grab
10 Room 6 Faucet	9-17-2020	5:46	Grab
11 Room 6 Bubbler	9-17-2020	5:46	Grab
12 Room 7 Faucet	9-17-2020	5:50	Grab
13 Room 7 Bubbler	9-17-2020	5:50	Grab
14 Room 23 Faucet	9-17-2020	5:57	Grab
15 Room 23 Bubbler	9-17-2020	5:57	Grab
16 Lower B section Bubbler	9-17-2020	5:59	Grab
17 Room 101 Faucet	9-17-2020	6:10	Grab
18 Room 101 Bubbler	9-17-2020	6:10	Grab
19 Room 102 Faucet	9-17-2020	6:13	Grab
20 Room 102 Bubbler	9-17-2020	6:13	Grab

Receiving Info (Lab Use Only)	
Ice:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Cooler:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Sample Temp:	_____
Cooler Seal:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Pickup:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Dropoff:	C <input type="checkbox"/> W <input type="checkbox"/>
Accepted?	YES <input type="checkbox"/> NO <input type="checkbox"/>
Container Material	_____
Container Size (in Ml)	_____
Preservative	_____

Analysis Requested		Number of Containers for Analysis Requested		Comments/Field Data	
Matrix	Type	Count	Notes	Comments	Field Data
Total Lead (EPA 200.8)		1			
Plastic		1			
250 ml		1			
HINO3		1			

Print Name and Company		Date/Time	Comments
Jennifer Walker		9/28/2020 11:04	
Sampled:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Corland, NY 13045
 Phone: (607) 753-3403 Fax: (607) 753-3415
 NY #10795, EPA #NY00863

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder # _____

Client Information		Billing/Invoice:	
Name: Afton CSD		Same as Client	
Address: PO Box 5, 29 Academy St Afton, NY 13730-0005			
Contact: Brian Phetteplace			
Phone: 607-639-8220			
Project: Main Building			
Quote ID:	PO#	Date Req:	
Rush TAT Bus. Days: < 2-5 5-7 7-10			
Carbon Copy: Yes			
Email Results: Yes			
Fax Results: Yes			
Email Results: bpchetteplace@aftoncsd.org			
Fax Results: 607-639-1801			
Sample Information			
Description/Location	Date	Time	Matrix Type
1 Room 103 Faucet	9-17-2020	6:15	Grab
2 Room 103 Bubbler	9-17-2020	6:15	Grab
3 Room 104 Faucet	9-17-2020	6:18	Grab
4 Room 104 Bubbler	9-17-2020	6:18	Grab
5 Room 105 Faucet	9-17-2020	6:35	Grab
6 Room 105 Bubbler	9-17-2020	6:35	Grab
7 Room 106 Faucet	9-17-2020	6:36	Grab
8 Room 106 Bubbler	9-17-2020	6:36	Grab
9 Room 107 Faucet	9-17-2020	6:41	Grab
10 Room 107 Bubbler	9-17-2020	6:41	Grab
11 Hall E. Craft Bubbler	9-17-2020	6:43	Grab
12 Elem. Kitchen Faucet A	9-17-2020	6:45	Grab
13 Elem. Kitchen Faucet B	9-17-2020	6:45	Grab
14 Elem. Kitchen Faucet C	9-17-2020	6:45	Grab
15 Room 110 Faucet	9-17-2020	6:50	Grab
16 Elem. Teacher Room Faucet	9-15-2020	7:25	Grab
17 Copy Room Faucet	9-15-2020	7:28	Grab
18 Room 202 Faucet	9-15-2020	6:45	Grab
19 Room 202 Bubbler	9-15-2020	6:45	Grab
20 Room 203 Faucet	9-15-2020	6:47	Grab

Analysis Requested		Receiving Info (Lab Use Only)	
Total Lead (EPA 200.8)		Ice: YES NO	YES NO
		Cooler: YES NO	YES NO
		Sample Temp:	
		Cooler Seal: YES NO	YES NO
		Pickup: YES NO	YES NO
		Dropoff: C W	
		Accepted? YES NO	YES NO
		Container Material	
		Container Size (in MI)	
		Preservative	
		Number of Containers for Analysis Requested	Comments/Field Data
			First Draw

Print Name and Company		Date/Time	Comments
Applied:			
Received:			
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested	
Name: Afton CSD		Same as Client			
Address: PO Box 5, 29 Academy St Afton, NY 13730-0005					
Contact: Brian Phetteplace 607-639-8220					
Project: Main Building		PO#:			
Quote ID:		Date Req.:			
Rush TAT Bus. Days: < 2-5 5-7 7-10					
Carbon Copy: Yes					
Email Results: Yes		bphetteplace@aftoncsd.org			
Fax Results: Yes		607-639-1801			
Sample Information					
#	Description/Location	Date	Time	Matrix Type	Number of Containers for Analysis Requested
1	Room 203 Bubbler	9-15-2020	6:47	Grab	1
2	Room 204 Faucet	9-15-2020	6:50	Grab	1
3	Room 204 Bubbler	9-15-2020	6:50	Grab	1
4	Room 205 Faucet	9-15-2020	6:54	Grab	1
5	Room 205 Bubbler	9-15-2020	6:54	Grab	1
6	Room 206 Faucet	9-15-2020	6:57	Grab	1
7	Room 206 Bubbler	9-15-2020	6:57	Grab	1
8	Room 207 Faucet	9-15-2020	7:00	Grab	1
9	Room 207 Bubbler	9-15-2020	7:00	Grab	1
10	Room 208 Faucet	9-15-2020	7:05	Grab	1
11	Room 208 Bubbler	9-15-2020	7:05	Grab	1
12	Room 209 Faucet	9-15-2020	7:08	Grab	1
13	Room 209 Bubbler	9-15-2020	7:08	Grab	1
14	Room 210 Faucet	9-15-2020	7:10	Grab	1
15	Room 210 Bubbler	9-15-2020	7:10	Grab	1
16	Room 211 Faucet	9-15-2020	7:14	Grab	1
17	Room 211 Bubbler	9-15-2020	7:14	Grab	1
18	Elem. 2nd Floor Bubbler	9-15-2020	7:10	Grab	1
19	Room 212 Faucet	9-15-2020	7:15	Grab	1
20	Room 212 Bubbler	9-15-2020	7:15	Grab	1
Receiving Info (Lab Use Only)					
Ice: YES NO					
Cooler: YES NO					
Sample Temp: YES NO					
Cooler Seal: YES NO					
Pickup: YES NO					
Dropoff: C W					
Accepted? YES NO					
Container Material					
Container Size(In MI)					
Preservative					
Comments/Field Data					
First Draw					
Total Lead (EPA 200.8)					
Plastic					
250 ml					
HNO3					
Date/Time					
Comments					
Print Name and Company					
Sampled:					
Received:					
Received:					

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00835

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoice:		Analyses Requested				Receiving Info (Lab Use Only)	
Name: Afton CSD		Same as Client						Ice: YES NO	
Address: PO Box 5, 29 Academy St Afton, NY 13730-0005								Cooler: YES NO	
Contact: Brian Phetteplace								Sample Temp: YES NO	
Phone: 607-639-8220								Cooler Seal: YES NO	
Project: Main Building								Pickup: YES NO	
Quote ID: PO#:								Dropoff: C W	
Ruth TAT Bus. Days: 2-5 5-7 7-10		Date Req.:						Accepted? YES NO	
Carbon Copy: Yes								Container Material	
Email Results: Yes		bphetteplace@aftoncsd.org						Container size(in MI)	
Fax Results: Yes		607-639-1801						Preservative	
Sample Information				Number of Containers for Analysis Requested				Comments/Field Data	
Description/Location		Date	Time	Matrix	Type				
1	Room 213 Faucet	9-15-2020	7:15	Grab	Grab	1			First Draw
2	Room 213 Bubblers	9-15-2020	7:15	Grab	Grab	1			
3	Room 214 Faucet	9-15-2020	7:18	Grab	Grab	1			
4	Room 214 Bubblers	9-15-2020	7:18	Grab	Grab	1			
5	2nd Floor 6th grade Bubbler A	9-15-2020	7:20	Grab	Grab	1			
6	2nd Floor 6th grade Bubbler B	9-16-2020	7:20	Grab	Grab	1			
7	Room 122 Faucet	9-15-2020	7:30	Grab	Grab	1			
8	Laundry Room Faucet	9-15-2020	7:35	Grab	Grab	1			
9	Laundry Room Ice machine	9-15-2020	7:35	Grab	Grab	1			
10	Hall between Pool & Gym Bubbler	9-15-2020	7:40	Grab	Grab	1			
11	Nurse's Office Faucet A	9-15-2020	6:33	Grab	Grab	1			
12	Nurse's Office Faucet B	9-15-2020	6:33	Grab	Grab	1			
13	H.S. Teachers Room Faucet	9-15-2020	6:35	Grab	Grab	1			
14	Hall by H.S. Café Bubbler	9-15-2020	8:40	Grab	Grab	1			
15	H.S. café Faucet A	9-15-2020	5:30	Grab	Grab	1			
16	H.S. café Faucet B	9-15-2020	5:30	Grab	Grab	1			
17	H.S. café Faucet C	9-15-2020	5:30	Grab	Grab	1			
18	H.S. café Faucet D	9-15-2020	5:30	Grab	Grab	1			
19	H.S. café Faucet E	9-15-2020	5:30	Grab	Grab	1			
20	H.S. café Ice Machine			Grab	Grab	1			
Total Lead (EPA 200.8)									
Plastic									
250 ml									
HNO3									

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoicing		Analysis Requested						Receiving Info (Lab Use Only)			
Name:	Afton CSD	Same as Client								Ice:	YES NO		
Address:	PO Box 5, 29 Academy St Afton, NY 13730-0005									Cooler:	YES NO		
Contact:	Brian Phetteplace 607-639-8220									Sample Temp:	YES NO		
Phone:										Cooler seal:	YES NO		
Project:	Main Building									Pickup:	YES NO		
Quote ID:	PO#:									Dropoff:	C W		
Rush TAT Bus. Days: 2 2-5 5-7 7-10	Date Req.:									Accepted?	YES NO		
Carbon Copy: Yes										Container Material			
Email Results: Yes	bphetteplace@aftoncsd.org									Container size (in ml)			
Fax Results: Yes	607-639-1801									Preservative			
Sample Information				Number of Containers for Analysis Requested						Comments/Field Data			
	Description/Location	Date	Time							First Draw			
1	Home Ec. Faucet A	9-15-2020	5:45	1									
2	Home Ec. Faucet B	9-15-2020	5:45	1									
3	Home Ec. Faucet C	9-15-2020	5:45	1									
4	Home Ec. Faucet D	9-15-2020	5:45	1									
5	Home Ec. Faucet E	9-15-2020	5:45	1									
6	Home Ec. Faucet F	9-15-2020	5:45	1									
7	Room 151 Faucet	9-15-2020	5:20	1									
8	Hall by Aud. Bubbler A	9-15-2020	5:45	1									
9	Hall by Aud. Bubbler B	9-15-2020	5:45	1									
10	Hall by Art Room Bubbler	9-15-2020	5:50	1									
11	GED Room Faucet	9-15-2020	5:53	1									
12	Bus garage Faucet	9-15-2020	5:10	1									
13	Room 34 Faucet A	9-15-2020	6:25	1									
14	Room 34 Faucet B	9-15-2020	6:25	1									
15	Main lobby Bubbler A	9-15-2020	6:15	1									
16	Main lobby Bubbler B	9-15-2020	6:15	1									
17	H.S. Boy's Locker room Bubbler	9-15-2020	6:20	1									
18	H.S. Girl's Locker room Bubbler	9-15-2020	6:20	1									
19	Over Look Bubbler	9-15-2020	6:10	1									
20	Band Room Faucet	9-15-2020	6:00	1									
Print Name and Company				Date/Time	Comments								
Sampled:													
Received:													
Received:													

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc.

CHAIN OF CUSTODY

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10796, EPA #NY00936

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoice:		Analysis Requested				Receiving Info (Lab Use Only)			
Name: Afton CSD		Same as Client						Ice: YES NO			
Address: PO Box 5, 29 Academy St Afton, NY 13730-0005								Cooler: YES NO			
Contact: Brian Petteplace								Sample Temp: YES NO			
Phones: 607-639-8220								Cooler Seal: YES NO			
Project: Main Building								Pickup: YES NO			
Quote ID: PO#								Dropoff: C W			
Rush TAT Bus. Days: 2-5 5-7 7-10		Date Req:						Accepted? YES NO			
Carbon Copy: Yes								Container Material			
Email Results: Yes		bphetteplace@aftoncsd.org						Container size (in ml)			
Fax Results: Yes		607-639-1801						Preservative			
Sample Information		Date		Time		Matrix		Number of Containers for Analysis Requested		Comments/Field Data	
Description/Location		Date		Time		Matrix		Number of Containers for Analysis Requested		Comments/Field Data	
1	Cust. Break room Faucet	9-15-2020	5:10 AM	Grab	1						
2	Pool area Bubbler	9-15-2020	6:30	Grab	1						
3	Hall by H.S. cafe Bottle fill	9-15-2020	5:40	Grab	1						
4	Over look Bottle fill	9-15-2020	6:10	Grab	1						
5	Over look Bottle fill			Grab	1						
6				Grab	1						
7				Grab	1						
8				Grab	1						
9				Grab	1						
10				Grab	1						
11				Grab	1						
12				Grab	1						
13				Grab	1						
14				Grab	1						
15				Grab	1						
16				Grab	1						
17				Grab	1						
18				Grab	1						
19				Grab	1						
20				Grab	1						
Total Lead (EPA 200.8)											
Plastic											
250 ml											
HNO3											

Print Name and Company
 Date/Time
 Comments
 Sampled:
 Received:
 Received:

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.